



WEST OF ENGLAND **FIRE** PROTECTION LIMITED



Unit 4, Taw Trade Park, Braunton Road
Barnstaple, North Devon. EX31 1JZ

Tel: 01271 377394 Fax: 01271 321711 Email: info@westfire.co.uk

Certificate of Inspection

VALID UNTIL THE LAST DAY OF THE CALENDAR MONTH - 12 MONTH FROM THE DATE OF ISSUE

CUSTOMERS NAME & ADDRESS

M.A.T.A. Regal Theatre Co Ltd
The Avenue
Minehead
Somerset
TA24 5UQ

ENGINEER

Sean Lowe

DATE OF ISSUE

21-02-2021

SERVICE AGREEMENT NUMBER

WE5640

EQUIPMENT LISTING

- 2 X Fire Blanket (Inspected)
- 2 X 3lt Foam Extinguisher (Basic Service)
- 1 X 2kg Carbon Dioxide Extinguisher (H-Test Due - NOT MAINTAINED)
- 1 X 5kg Carbon Dioxide Extinguisher (Basic Service)
- 2 X 6lt Water Extinguisher (Extended Service)
- 1 X 2kg Carbon Dioxide Extinguisher (Unavailable for Service-)
- 3 X 9lt Water Extinguisher (Basic Service)
- 8 X 2kg Carbon Dioxide Extinguisher (Basic Service)
- 6 X 6lt Water Extinguisher (Basic Service)
- 1 X 6lt Eco Foam Extinguisher (27a) (New A - Commissioned)
- 3 X 2kg Carbon Dioxide Extinguisher (New A - Commissioned)
- 1 X 6lt Water Extinguisher (New A - Commissioned)

Guidance To Clients (BS5306 Part 3) Monthly Inspection.

It is strongly recommended that in addition to this annual service that a regular visual inspection of all fire extinguishers is carried out at intervals of at least monthly, to ensure that all appliances are in their proper positions and have not been discharged or suffered any obvious damage

**This certificate confirms that the equipment listed above has been serviced in
Accordance with BS5306: Part 3 2017 and passed fit for service**



Any non-conforming equipment will be listed on a separate rectification form

